

**PROJECT NAME:** Centennial Park Phase III  
**BID No:** 2010-03  
**DATE:** October 28, 2009  
**CLARIFICATION ISSUED BY:**  
Jim Row, Community Services Director  
**REPORT NO.:** One (1)

**QUESTIONS:**

1. Sheet C2.1 shows the concrete at the center of the ball fields to reference detail 3/C8.1. Sheet L3.3 shows this same area to reference detail 2/C8.1. Which is correct?

**CLARIFICATION:**

1. Sheet C2.1 is correct. Concrete in the center of the ball fields must accommodate vehicles so the thicker section is appropriate, thus key note #1 should reference detail 3/C8.1 on sheet L3.3 only.